


## Building Safety Certificate

The School Building of Galaxy Public School Railway Road Nagrota Surian Distt. Kangra (H.P) was inspected by me with the concerned Junior Engineer. The building has neither been designed nor constructed by this department. No earthquake resistance norms have been adopted for this building. No structure drawing approved by the competent Government agency has been produced. The structure is a non engineering structure. Hence the structure safety of this building can not be ensured specially for the earthquake point of view. The building is constructed in the year 2003. The department will not be responsible for any type of loss of life and property etc, If the structure falls under any circumstances.

However as per visual inspection, the building appears to be safe at present only. No officer/ official of this department will attend please in any Hon'ble court of law in case of any dispute. This certificate is valid from 01-04-2022 to 31-03-2025. As per notification received from the Addl. Chief Secretary (PW) to the Government of Himachal Pradesh vide letter No. PBW(B)E95/2019 Dated 05 05 2021.

Dated: 13, Apr, 2022 

Place: Nagrota Surian

  
Assistant Engineer,  
Nagrota Surian Sub Division  
HPPWD Nagrota Surian

  
Executive Engineer,  
Jawan Division, HP PWD  
Jawali.